

**EU DECLARATION OF CONFORMITY – No CETF033 rev1**

**Manufacturer:** Tunstall Healthcare (UK) Ltd  
Whitley Lodge, Whitley Bridge  
Yorkshire, DN14 0HR  
UK  
Tel: +44 1977 661234

This declaration is issued under the sole responsibility of the manufacturer.  
The manufacturer declares under our own responsibility that the following radio product:

Product name:	Product number:	Product Description:
Heat Detector	68005/71	Heat Alarm 869

comply with the requirements of the following directive(s)

- 2014/53/EU Radio Equipment Directive (RED)**
- 2011/65/EU Restriction of the use of certain hazardous substances (RoHS)**

The conformity was checked in accordance with the following harmonised EN standard(s):


- EN 300 220-2:V3.1.1 (2017) EMC and Radio Spectrum Matters; Short Range Devices**
- EN 55032:2012: Electromagnetic compatibility of multimedia equipment. Emission Requirements**
- EN 50130-4: 2011 EMC Product Family Standard; Immunity Requirements for Components of Fire, Intruder and Social Alarm Systems**
- EN 60950-1: 2006/A12:2011 Safety of Information Equipment**

The heat alarm complies with the following Fire Safety standard: **BS 5446-2:2003**

Signed

Date

  
Mark Jennings



Position: Chief Engineer, Tunstall Healthcare (UK) Ltd